

U S E R G U I D E

CAVIUS
WIRELESS)))
ALARM FAMILY



SMOKE
A L A R M

Optical smoke alarm device
Model no.: 2106

The smoke alarm is designed for private homes.

PLEASE READ THE USER GUIDE CAREFULLY BEFORE INSTALLATION AND RETAIN FOR FUTURE USE.

SAFETY INSTRUCTIONS:

The device comes with a 3V lithium battery. Batteries are to be handled with care and battery powered devices should be kept out of reach of children. Do not try to recharge or burn the batteries.

1. TEST FUNCTION:

After installation, and at least once per quarter, test all of your alarms to ensure they are operating correctly and are within range of each other.

It is recommended to check visually every week if the LED flashes correctly (every 48sec.)

Press the test button on any alarm for at least 10 seconds. This will send out a test signal from the alarm; all other connected alarms should receive the signal within a short time. The alarms will emit a short beep and the LED will flash every 8 seconds for 2 minutes.

NOTE: Test function also allows to send a depleted RF signal to ensure an optimal operation in normal conditions.

When the test signal is sent out, the alarms will respond in two ways:

1. A single beep every 8 seconds indicates that the alarms are connected and functioning.

2. Three short beeps every 8 seconds indicates a smoke sensor fault. The alarm should be cleaned by running the vacuum (on a low setting) around the smoke alarm chamber and tested again.

If required this indication can be stopped early on each alarm by a short press of the test button.

TIP: It is safe to cover the sound output hole with your finger during the testing to minimize the sound level emitted.

If the problem continues, please visit www.cavius.com for any trouble shooting.

2. NORMAL MODE:

In normal mode the LED will flash every 48 seconds to show correct operation.

3. ALARM MODE:

When a concentration of smoke is detected, the smoke alarm will go into 'Alarm Mode'. It will sound the alarm signal and the LED will flash.

The smoke alarm will also transmit the alarm signal to the other connected alarms, which will also sound the alarm signal after a short delay.

The CAVIUS Wireless Family have two different alarm signals:

Alarm signal 1 (--- ---) is life threatening alarms.

Alarm signal 2 (- - -) is a non life threatening alarm.

Smoke alarm signal: --- ---

Heat alarm signal: - - -

Please note that only the originating alarm's LED will flash, so it can be identified.

4. PAUSE/HUSH FUNCTION:

If the smoke alarms are to set into a false alarm by cooking, fireplace, etc. they can be paused for 10 minutes by pressing the test button on the originating smoke alarm only (indicated by the flashing LED).

The reason of this is that it is necessary to locate the source of the alarm before using the hush function. This is to make sure that it is not a life threatening situation.

5. LOW BATTERY SIGNAL:

Your product has a 10Y battery life. When the battery is starting its end of life, a short beep will sound out every 48 seconds for 30 days.

The alarm affected by the low battery will only beep, no other connected alarms will sound.

It is recommended to replace the smoke alarm after 10 years, or if the alarm has suffered any damage. The alarm is not active unless it is inserted in the mounting base.

Always check the alarm after inserting in the mounting base (allow a few seconds before testing).

6. MAINTENANCE & TROUBLE SHOOTING:

• The smoke alarm should be vacuum cleaned once per quarter, to remove dust particles, and it can be wiped with a damp cloth. (Do not open the alarm).

• High humidity condensing which can be resolved by drying the smoke alarm.

If the smoke alarm does not work when the test button is pushed, the probable cause is a faulty battery. Check if the battery is depleted by pushing the test button

If the problem continues, please visit www.cavius.com for any trouble shooting.

7. OTHER INFORMATION:

Do not paint the alarm.

Complies to the Radio Equipment Directive 2014/53/EU

RF Frequency: 868 MHz.

Maximum radio-frequency power transmitted: 20 mW

Full DoC to 2014/53/EU (RED) can be downloaded at www.cavius.com

WARNING: All alarms should be assumed as due to actual fire and the dwelling should be evacuated immediately.

WARNING: To prevent injury, this apparatus must be permanently fixed to the ceiling/wall in accordance with the installation instructions.


WARNING: Batteries shall not be exposed to excessive heat such as shine, fire, or the like. Note the local country regulations regarding installation.

Disposal: please dispose properly at the end of life. This is electronic waste which should be recycled.

Please note local regulations about information to your insurance company regarding installed smoke alarms.

Hereby, Cavius declares that the radio equipment type 2106 is in compliance with Directive 2014/53/EU.

The full text of the EU declaration of conformity is available at the following internet address: www.cavius.com



The CE and RED declaration of conformity and DoP can be downloaded from: <http://www.cavius.com>
The paper version of the DoP is available free of charge upon request.



Carrier assumes no responsibility for any errors, which may appear in this manual. Furthermore, Carrier reserves the right to alter the hardware, software, and/or specifications detailed herein at any time without notice, and Carrier does not make any commitment to update the information contained herein.

Manufacturer: Carrier Fire & Security Danmark A/S, Ellekær 9A, 2. Th, DK-2730. Made in China.